



CERTIFICATE OF ANALYSIS

FOR

Total Viable Counts

The following samples were analysed by an Independent UKAS Accredited Laboratory

Sample	Lab No	Sample Date	Colonies 1 day 37°C cfu/ml	Total coliforms cfu/100ml	E. coli cfu/100ml	Pseudomonas aeruginosa cfu/100ml
Pool	SBN4881743	20/07/2020	0	0	0	0
PWTAG/BSI (pool) limits:			10	0	0	10
PHLS (spa) limits:			10	0	0	0

Comments: All bacterial results highly satisfactory.

Client: Dulwich College Sports Club
 Site: Dulwich College
 Pond Cottages
 Dulwich Common
 London
 SE21 7LD

Responsible Person: Mr Gary Sharpe

Signed on behalf of Kingfisher Environmental Services Ltd.

Date: 31 July 2020

Certificate Reference No: PO563118/DCS/SYS



Company Registered in Wales
 No. 3823185 Vat No. 740675037

